



ARGB – KVBG

The ARGB-KVBG laboratory certifies the conformity with Belgian requirements for the PLT tubing kit.
Le laboratoire de l'ARGB certifie que le kit de tuyaux PLT est conforme aux exigences Belges.
Het laboratorium van de KVBG verklaart dat het PLT buissysteem conform is aan de Belgische eisen.

Certificate Number : **C-16-3737-A (linked with C-16-3697-A)**
N° du certificat :
Certificaat nummer :

Date of issue : **17/05/2016**
Date d'édition :
Datum van aflevering :

Manufacturer : **Omegaflex Limited**
Fabricant :
Fabrikant : **Kildare House, Wildmere Road
Banbury OX16 3JU, UK**

Distributor : **Cynerpro**
Distributeur :
Verdeler: **Haverheidelaan 13A
B-9140 Temse**

Scope : **■ Low pressure gas installations according to the standard NBN D51-003 with
MOP ≤ 100 mbar and diameter ≤ DN50**
Domaine d'application :
Toepassingsgebied : **■ Installations à gaz basse pression suivant la norme NBN D51-003 avec
MOP ≤ 100 mbar and diameter ≤ DN50**
**■ Lage druk gasinstallaties volgens de norm NBN D 51-003 met MOP ≤ 100 mbar
en diameter ≤ DN50**

Requirements: **NBN EN 15266 'Stainless steel pliable corrugated tubing kits in buildings for gas
with an operating pressure up to 0,5 bar'**
Exigences :
Eisen :

Certigaz – certificate:	ATG PLT 002-03	(11/09/2015)
BSI - certificate:	KM 549666	(20/10/2010)
SETS – report:	Report N341	(15/07/2009)
GL industrial services – report:	TR/09/270/Rev3	(19/08/2009)
BSI – report:	285/7362283	(08/09/2009)
Chiltern – report:	Chilt/B07002/1	(02/08/2007)
Chiltern – report:	Chilt/B07002/2	(02/08/2007)

Type:

TracPipe

Stainless steel pliable corrugated tubing kits for gas

Kits de tuyaux onduleux pliables en acier inoxydable pour le gaz

Roestvast stalen buigzame gegolfde buissystemen voor gas

MOP: 0,5 bar / GT: 0,1 bar

DN: 10 – 15 – 20 – 25 – 32 – 40 – 50

Thread EN 10226-1 R / R_p: 3/8" – 1/2" – 3/4" – 1" – 5/4" – 6/4" – 2"

Model FGP-SS4

Stainless steel pliable corrugated tube

Model FGP-FST

Fitting, PLT end / male thread

Model FGP-BSP

Fitting, PLT end / female thread

Model FGP-CPLG

Fitting, 2 x PLT end

Model FGP-TF

Tee, 3 x PLT end

Model FGP-RT

Tee, 3 x PLT end reduced



Kenny VANLANCKER
Laboratory Manager.